

## Declaration of Hygiene Conformity

### Flow Rate Measuring Units Made of Plastic Type VMLK

#### Object of the inspection

TROX GmbH, Heinrich-Trox-Platz, D-47504 Neukirchen-Vluyn, Germany, hereby confirm that the Flow Rate Measuring Units made of plastic of type VMLK meet the hygiene requirements specified by the standards and regulations listed below.

- European standard
  - EN 13779 (09/2007)
- German standards
  - VDI 6022, part 1 (07/2011)
  - VDI 3803 (02/2010)
  - DIN 1946, part 4 (12/2008)
- Austrian standards
  - ÖNORM H 6021 (09/2003)
  - ÖNORM H 6020 (02/2007)
- Swiss SWKI regulations
  - VA104-01 (04/2006)
  - 99-3 (04/2003)

For the purpose of this declaration of conformity a sample of each type mentioned above was viewed at the TROX GmbH factory, Gendringer Straße 85, D-46419 Isselburg-Anholt, Germany, and related data sheets, technical literature, and inspection reports were appraised.

#### Summary of the test result

The examination of the above-mentioned sample equipment and the appraisal of the available documents have shown that the hygiene requirements specified by the above-mentioned standards and regulations are met.

**We hereby confirm that the Flow Rate Measuring Units made of plastic of type VMLK meet the hygiene requirements of the specified standards and regulations.**

Neukirchen-Vluyn, Germany, 19 May 2014



Jörg Slawinski  
trained according to VDI 6022, category A  
Product Management



Dipl.-Ing. Jan Heymann

Manager Quality Systems

Certificate